



Perspective

\* Can be installed in any inlet without a curb box

Notes

1. Manufactured alternatives approved and listed on the department's erosion control product acceptability list may be substituted.
2. When removing or maintaining inlet protection, care shall be taken so that the sediment trapped on the geotextile fabric does not fall into the inlet. Any material falling into the inlet shall be removed immediately.
- ③ Finished size, including flap pockets where required, shall extend a minimum of 10" around the perimeter to facilitate maintenance or removal.
4. For Type B:  
Trim excess fabric in the flow line to 3" of the grate. The contractor shall demonstrate a method of maintenance, using a sewn flap, hand holds, or other method to prevent accumulated sediment from entering the inlet. Type B may only be utilized after casting and grate are placed.
5. Inlet protection shall be inspected weekly (at a minimum) and within 24 hours after each rain event of 0.5 inches or greater. Inlet protection shall be maintained or replaced at the direction of the city.
6. For more information see WDNR Tech Std #1060.



**Inlet Protection Type B**

Date Revised  
August 2014

Plate Number  
3125-05

Sheet 1 of 1

