



Elevation

Note:
 4'-0" min. unless valve requires larger.

All manholes to be CL 3 RCP ASTM Spec C 478.

All fittings inside valve manholes to flanged fittings.

To be used only with permission of RFMU.



Valve Manhole

Date Revised August 2014
Plate Number 3310-10
Sheet 1 of 1

