

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 2023

Influent Flow and Loading

1. Monthly Average Flows and BOD Loadings

1.1 Verify the following monthly flows and BOD loadings to your facility.

Influent No. 701	Influent Monthly Average Flow, MGD	x	Influent Monthly Average BOD Concentration mg/L	x	8.34	=	Influent Monthly Average BOD Loading, lbs/day
January	1.2690	x	238	x	8.34	=	2,516
February	1.3241	x	250	x	8.34	=	2,764
March	1.3108	x	259	x	8.34	=	2,829
April	1.4593	x	246	x	8.34	=	2,993
May	1.3529	x	223	x	8.34	=	2,512
June	1.2928	x	228	x	8.34	=	2,459
July	1.2810	x	241	x	8.34	=	2,576
August	1.2886	x	229	x	8.34	=	2,462
September	1.3537	x	239	x	8.34	=	2,699
October	1.3709	x	238	x	8.34	=	2,720
November	1.3499	x	237	x	8.34	=	2,664
December	1.3480	x	229	x	8.34	=	2,569

2. Maximum Monthly Design Flow and Design BOD Loading

2.1 Verify the design flow and loading for your facility.

Design	Design Factor	x	%	=	% of Design
Max Month Design Flow, MGD	1.98	x	90	=	1.782
		x	100	=	1.98
Design BOD, lbs/day	3898	x	90	=	3508.2
		x	100	=	3898

2.2 Verify the number of times the flow and BOD exceeded 90% or 100% of design, points earned, and score:

	Months of Influent	Number of times flow was greater than 90% of	Number of times flow was greater than 100% of	Number of times BOD was greater than 90% of design	Number of times BOD was greater than 100% of design
January	1	0	0	0	0
February	1	0	0	0	0
March	1	0	0	0	0
April	1	0	0	0	0
May	1	0	0	0	0
June	1	0	0	0	0
July	1	0	0	0	0
August	1	0	0	0	0
September	1	0	0	0	0
October	1	0	0	0	0
November	1	0	0	0	0
December	1	0	0	0	0
Points per each		2	1	3	2
Exceedances		0	0	0	0
Points		0	0	0	0
Total Number of Points					0

0

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 2023

3. Flow Meter

3.1 Was the influent flow meter calibrated in the last year?

Yes Enter last calibration date (MM/DD/YYYY)

No

If No, please explain:

4. Sewer Use Ordinance

4.1 Did your community have a sewer use ordinance that limited or prohibited the discharge of excessive conventional pollutants ((C)BOD, SS, or pH) or toxic substances to the sewer from industries, commercial users, hauled waste, or residences?

Yes

No

If No, please explain:

4.2 Was it necessary to enforce the ordinance?

Yes

No

If Yes, please explain:

5. Septage Receiving

5.1 Did you have requests to receive septage at your facility?

Septic Tanks Holding Tanks Grease Traps

Yes

Yes

Yes

No

No

No

5.2 Did you receive septage at your facility? If yes, indicate volume in gallons.

Septic Tanks

Yes gallons

No

Holding Tanks

Yes gallons

No

Grease Traps

Yes gallons

No

5.2.1 If yes to any of the above, please explain if plant performance is affected when receiving any of these wastes.

6. Pretreatment

6.1 Did your facility experience operational problems, permit violations, biosolids quality concerns, or hazardous situations in the sewer system or treatment plant that were attributable to commercial or industrial discharges in the last year?

Yes

No

If yes, describe the situation and your community's response.

6.2 Did your facility accept hauled industrial wastes, landfill leachate, etc.?

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 2023

<p><input type="radio"/> Yes</p> <p><input checked="" type="radio"/> No</p> <p>If yes, describe the types of wastes received and any procedures or other restrictions that were in place to protect the facility from the discharge of hauled industrial wastes.</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	
--	--

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 2023

Effluent Quality and Plant Performance (BOD/CBOD)

1. Effluent (C)BOD Results

1.1 Verify the following monthly average effluent values, exceedances, and points for BOD or CBOD

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit > 10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	30	27	10	1	0	0
February	30	27	13	1	0	0
March	30	27	13	1	0	0
April	30	27	9	1	0	0
May	30	27	7	1	0	0
June	30	27	6	1	0	0
July	30	27	7	1	0	0
August	30	27	6	1	0	0
September	30	27	6	1	0	0
October	30	27	8	1	0	0
November	30	27	6	1	0	0
December	30	27	6	1	0	0

* Equals limit if limit is <= 10

Months of discharge/yr	12		
Points per each exceedance with 12 months of discharge		7	3
Exceedances		0	0
Points		0	0
Total number of points			0

0

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge. Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

2. Flow Meter Calibration

2.1 Was the effluent flow meter calibrated in the last year?

Yes Enter last calibration date (MM/DD/YYYY)

2024-03-06

No

If No, please explain:

3. Treatment Problems

3.1 What problems, if any, were experienced over the last year that threatened treatment?

No problems

4. Other Monitoring and Limits

4.1 At any time in the past year was there an exceedance of a permit limit for any other pollutants such as chlorides, pH, residual chlorine, fecal coliform, or metals?

Yes

No

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 2023

If Yes, please explain:

4.2 At any time in the past year was there a failure of an effluent acute or chronic whole effluent toxicity (WET) test?
 Yes
 No

If Yes, please explain:

4.3 If the biomonitoring (WET) test did not pass, were steps taken to identify and/or reduce source(s) of toxicity?
 Yes
 No
 N/A

Please explain unless not applicable:

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 2023

Effluent Quality and Plant Performance (Total Suspended Solids)

1. Effluent Total Suspended Solids Results

1.1 Verify the following monthly average effluent values, exceedances, and points for TSS:

Outfall No. 001	Monthly Average Limit (mg/L)	90% of Permit Limit >10 (mg/L)	Effluent Monthly Average (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance	90% Permit Limit Exceedance
January	30	27	6	1	0	0
February	30	27	8	1	0	0
March	30	27	10	1	0	0
April	30	27	6	1	0	0
May	30	27	5	1	0	0
June	30	27	6	1	0	0
July	30	27	7	1	0	0
August	30	27	6	1	0	0
September	30	27	5	1	0	0
October	30	27	5	1	0	0
November	30	27	6	1	0	0
December	30	27	6	1	0	0

* Equals limit if limit is <= 10

Months of Discharge/yr	12		
Points per each exceedance with 12 months of discharge:		7	3
Exceedances		0	0
Points		0	0
Total Number of Points			0

0

NOTE: For systems that discharge intermittently to state waters, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.

Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 **2023**

Effluent Quality and Plant Performance (Ammonia - NH3)

1. Effluent Ammonia Results

1.1 Verify the following monthly and weekly average effluent values, exceedances and points for ammonia

Outfall No. 001	Monthly Average NH3 Limit (mg/L)	Weekly Average NH3 Limit (mg/L)	Effluent Monthly Average NH3 (mg/L)	Monthly Permit Limit Exceedance	Effluent Weekly Average for Week 1	Effluent Weekly Average for Week 2	Effluent Weekly Average for Week 3	Effluent Weekly Average for Week 4	Weekly Permit Limit Exceedance
January	5.7	7.5	1.431	0	.77	1.223	1.65	2.08	0
February	5.7	7.5	1.72	0	1.183	2.03	1.848	1.683	0
March	5.7	7.5	1.164	0	3.919	.847	.114	.116	0
April	5.7	7.5	.088	0	.117	.077	.067	.073	0
May	2	2	.104	0	.078	.197	.069	.084	0
June	2	2	.206	0	.071	.278	.077	.348	0
July	2	2	.119	0	.123	.087	.086	.181	0
August	2	2	.068	0	.106	.051	.077	.043	0
September	2	2	.132	0	.127	.079	.172	.149	0
October	2	2	.128	0	.094	.097	.067	.253	0
November	5.7	7.5	.107	0	.108	.085	.191	.064	0
December	5.7	7.5	.095	0	.057	.068	.189	.071	0
Points per each exceedance of Monthly average:									10
Exceedances, Monthly:									0
Points:									0
Points per each exceedance of weekly average (when there is no monthly average):									2.5
Exceedances, Weekly:									0
Points:									0
Total Number of Points									0

0

NOTE: Limit exceedances are considered for monthly OR weekly averages but not both. When a monthly average limit exists it will be used to determine exceedances and generate points. This will be true even if a weekly limit also exists. When a weekly average limit exists and a monthly limit does not exist, the weekly limit will be used to determine exceedances and generate points.

1.2 If any violations occurred, what action was taken to regain compliance?

--

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 2023

Effluent Quality and Plant Performance (Phosphorus)

1. Effluent Phosphorus Results

1.1 Verify the following monthly average effluent values, exceedances, and points for Phosphorus

Outfall No. 001	Monthly Average phosphorus Limit (mg/L)	Effluent Monthly Average phosphorus (mg/L)	Months of Discharge with a Limit	Permit Limit Exceedance
January	1	0.226	1	0
February	1	0.248	1	0
March	1	0.286	1	0
April	1	0.197	1	0
May	1	0.239	1	0
June	1	0.275	1	0
July	1	0.521	1	0
August	1	0.437	1	0
September	1	0.352	1	0
October	1	0.795	1	0
November	1	0.465	1	0
December	1	0.233	1	0
Months of Discharge/yr			12	
Points per each exceedance with 12 months of discharge:				10
Exceedances				0
Total Number of Points				0

0

NOTE: For systems that discharge intermittently to waters of the state, the points per monthly exceedance for this section shall be based upon a multiplication factor of 12 months divided by the number of months of discharge.
Example: For a wastewater facility discharging only 6 months of the year, the multiplication factor is $12/6 = 2.0$

1.2 If any violations occurred, what action was taken to regain compliance?

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 2023

Biosolids Quality and Management

1. Biosolids Use/Disposal

1.1 How did you use or dispose of your biosolids? (Check all that apply)

- Land applied under your permit
- Publicly Distributed Exceptional Quality Biosolids
- Hauled to another permitted facility
- Landfilled
- Incinerated
- Other

NOTE: If you did not remove biosolids from your system, please describe your system type such as lagoons, reed beds, recirculating sand filters, etc.

1.1.1 If you checked Other, please describe:

3. Biosolids Metals

Number of biosolids outfalls in your WPDES permit:

3.1 For each outfall tested, verify the biosolids metal quality values for your facility during the last calendar year.

Outfall No. 002 - SLUDGE TO WCWBF

Parameter	80% of Limit	H.Q. Limit	Ceiling Limit	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	80% Value	High Quality	Ceiling
Arsenic		41	75												<6.6		0	0
Cadmium		39	85												<.25		0	0
Copper		1500	4300												360		0	0
Lead		300	840												<5.8		0	0
Mercury		17	57												<1.9		0	0
Molybdenum	60		75												4.9	0		0
Nickel	336		420												13	0		0
Selenium	80		100												<16	0		0
Zinc		2800	7500												340		0	0

3.1.1 Number of times any of the metals exceeded the high quality limits OR 80% of the limit for molybdenum, nickel, or selenium = 0

Exceedence Points

- 0 (0 Points)
- 1-2 (10 Points)
- > 2 (15 Points)

3.1.2 If you exceeded the high quality limits, did you cumulatively track the metals loading at each land application site? (check applicable box)

- Yes
- No (10 points)
- N/A - Did not exceed limits or no HQ limit applies (0 points)
- N/A - Did not land apply biosolids until limit was met (0 points)

3.1.3 Number of times any of the metals exceeded the ceiling limits = 0

Exceedence Points

- 0 (0 Points)
- 1 (10 Points)
- > 1 (15 Points)

3.1.4 Were biosolids land applied which exceeded the ceiling limit?

- Yes (20 Points)
- No (0 Points)

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 2023

<p>3.1.5 If any metal limit (high quality or ceiling) was exceeded at any time, what action was taken? Has the source of the metals been identified?</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	0
<p>6. Biosolids Storage 6.1 How many days of actual, current biosolids storage capacity did your wastewater treatment facility have either on-site or off-site?</p> <ul style="list-style-type: none"> <input checked="" type="radio"/> >= 180 days (0 Points) <input type="radio"/> 150 - 179 days (10 Points) <input type="radio"/> 120 - 149 days (20 Points) <input type="radio"/> 90 - 119 days (30 Points) <input type="radio"/> < 90 days (40 Points) <input type="radio"/> N/A (0 Points) <p>6.2 If you checked N/A above, explain why.</p> <div style="border: 1px solid black; height: 20px; width: 100%;"></div>	0
<p>7. Issues 7.1 Describe any outstanding biosolids issues with treatment, use or overall management:</p> <div style="border: 1px solid black; padding: 2px;">No issues</div>	

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 2023

Staffing and Preventative Maintenance (All Treatment Plants)

1. Plant Staffing

1.1 Was your wastewater treatment plant adequately staffed last year?

- Yes
- No

If No, please explain:

Could use more help/staff for:

1.2 Did your wastewater staff have adequate time to properly operate and maintain the plant and fulfill all wastewater management tasks including recordkeeping?

- Yes
- No

If No, please explain:

2. Preventative Maintenance

2.1 Did your plant have a documented AND implemented plan for preventative maintenance on major equipment items?

- Yes (Continue with question 2)
- No (40 points)

If No, please explain, then go to question 3:

2.2 Did this preventative maintenance program depict frequency of intervals, types of lubrication, and other tasks necessary for each piece of equipment?

- Yes
- No (10 points)

2.3 Were these preventative maintenance tasks, as well as major equipment repairs, recorded and filed so future maintenance problems can be assessed properly?

- Yes
 - Paper file system
 - Computer system
 - Both paper and computer system
- No (10 points)

0

3. O&M Manual

3.1 Does your plant have a detailed O&M and Manufacturer Equipment Manuals that can be used as a reference when needed?

- Yes
- No

4. Overall Maintenance /Repairs

4.1 Rate the overall maintenance of your wastewater plant.

- Excellent
- Very good
- Good
- Fair
- Poor

Describe your rating:

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 2023

We are very proactive with keeping our equipment running efficiently and if it is unable to be repaired, we purchase new. We also have a diligent maintenance schedule we keep up with

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 2023

Operator Certification and Education

1. Operator-In-Charge

1.1 Did you have a designated operator-in-charge during the report year?

- Yes (0 points)
- No (20 points)

Name:

WILLIAM A SWENSON

Certification No:

33266

0

2. Certification Requirements

2.1 In accordance with Chapter NR 114.56 and 114.57, Wisconsin Administrative Code, what level and subclass(es) were required for the operator-in-charge (OIC) to operate the wastewater treatment plant and what level and subclass(es) were held by the operator-in-charge?

Sub Class	SubClass Description	WWTP	OIC		
		Advanced	OIT	Basic	Advanced
A1	Suspended Growth Processes	X			X
A2	Attached Growth Processes				
A3	Recirculating Media Filters				
A4	Ponds, Lagoons and Natural				
A5	Anaerobic Treatment Of Liquid				
B	Solids Separation	X			X
C	Biological Solids/Sludges	X			X
P	Total Phosphorus	X			X
N	Total Nitrogen				
D	Disinfection	X			X
L	Laboratory	X			X
U	Unique Treatment Systems				
SS	Sanitary Sewage Collection	X	NA	NA	NA

0

2.2 Was the operator-in-charge certified at the appropriate level and subclass(es) to operate this plant? (Note: Certification in subclass SS is required 5 years after permit reissuance.)

- Yes (0 points)
- No (20 points)

2.3 For wastewater treatment facilities with a registered or certified laboratory, is at least one operator that works in the laboratory certified at the basic level in the laboratory (L) subclass?

- Yes
- No
- N/A – Wastewater treatment facility does not have a registered or certified laboratory

2.4 For wastewater treatment facilities that own and operate a sanitary sewage collection system, has at least one operator been designated the OIC for sanitary sewage collection system and certified at the basic level in the sanitary sewage collection system (SS) subclass?

- Yes
- No
- N/A – Owner of the Wastewater treatment facility does not own and operate a sanitary sewage collection system

3. Succession Planning

3.1 In the event of the loss of your designated operator-in-charge, did you have a contingency plan to ensure the continued proper operation and maintenance of the plant that includes one or more of the following options (check all that apply)?

- One or more additional certified operators on staff

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 2023

<input type="checkbox"/> An arrangement with another certified operator <input type="checkbox"/> An arrangement with another community with a certified operator <input type="checkbox"/> An operator on staff who has an operator-in-training certificate for your plant and is expected to be certified within one year <input type="checkbox"/> A consultant to serve as your certified operator <input type="checkbox"/> None of the above (20 points) If "None of the above" is selected, please explain: <div style="border: 1px solid black; height: 20px; width: 100%; margin-top: 5px;"></div>	0
4. Continuing Education Credits 4.1 If you had a designated operator-in-charge, was the operator-in-charge earning Continuing Education Credits at the following rates? OIT and Basic Certification: <input type="radio"/> Averaging 6 or more CECs per year. <input type="radio"/> Averaging less than 6 CECs per year. Advanced Certification: <input checked="" type="radio"/> Averaging 8 or more CECs per year. <input type="radio"/> Averaging less than 8 CECs per year.	

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 2023

Financial Management

1. Provider of Financial Information

Name:

Scott Kosmo

Telephone:

715-426-3454

(XXX) XXX-XXXX

E-Mail Address
(optional):

skosmo@rfcity.org

2. Treatment Works Operating Revenues

2.1 Are User Charges or other revenues sufficient to cover O&M expenses for your wastewater treatment plant AND/OR collection system ?

- Yes (0 points)
- No (40 points)

If No, please explain:

2.2 When was the User Charge System or other revenue source(s) last reviewed and/or revised?
Year:

2023

0

- 0-2 years ago (0 points)
- 3 or more years ago (20 points)
- N/A (private facility)

2.3 Did you have a special account (e.g., CWF required segregated Replacement Fund, etc.) or financial resources available for repairing or replacing equipment for your wastewater treatment plant and/or collection system?

- Yes (0 points)
- No (40 points)

REPLACEMENT FUNDS [PUBLIC MUNICIPAL FACILITIES SHALL COMPLETE QUESTION 3]

3. Equipment Replacement Funds

3.1 When was the Equipment Replacement Fund last reviewed and/or revised?

Year:

2023

- 1-2 years ago (0 points)
- 3 or more years ago (20 points)
- N/A

If N/A, please explain:

3.2 Equipment Replacement Fund Activity

3.2.1 Ending Balance Reported on Last Year's CMAR

\$ 1,011,021.51

3.2.2 Adjustments - if necessary (e.g. earned interest, audit correction, withdrawal of excess funds, increase making up previous shortfall, etc.)

\$ 0.00

3.2.3 Adjusted January 1st Beginning Balance

\$ 1,011,021.51

3.2.4 Additions to Fund (e.g. portion of User Fee, earned interest, etc.)

+ \$ 51,994.57

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 2023

3.2.5 Subtractions from Fund (e.g., equipment replacement, major repairs - use description box 3.2.6.1 below*) - \$ 0.00

3.2.6 Ending Balance as of December 31st for CMAR Reporting Year \$ 1,063,016.08

All Sources: This ending balance should include all Equipment Replacement Funds whether held in a bank account(s), certificate(s) of deposit, etc.

3.2.6.1 Indicate adjustments, equipment purchases, and/or major repairs from 3.2.5 above.

3.3 What amount should be in your Replacement Fund? \$ 935,527.00

0

Please note: If you had a CFWP loan, this amount was originally based on the Financial Assistance Agreement (FAA) and should be regularly updated as needed. Further calculation instructions and an example can be found by clicking the SectionInstructions link under Info header in the left-side menu.

3.3.1 Is the December 31 Ending Balance in your Replacement Fund above, (#3.2.6) equal to, or greater than the amount that should be in it (#3.3)?

- Yes
- No

If No, please explain.

4. Future Planning

4.1 During the next ten years, will you be involved in formal planning for upgrading, rehabilitating, or new construction of your treatment facility or collection system?

- Yes - If Yes, please provide major project information, if not already listed below.
- No

Project #	Project Description	Estimated Cost	Approximate Construction Year
1	Sanitary Sewer Pipe Lining - This is an ongoing budget item to maintain an annual sewer slip lining program. This will improve the performance and extend the useful life of our existing collection system.	\$250,000	2022
2	Collection System Replacements - We are budgeting annually for ongoing sewer pipe replacements that are not able to be rehabilitated by slip lining. This will be an annual maintenance program for our system maintenance and adjusted for inflation. This also covers monoform repair of manholes.	\$150,000	2024
3	Replace chlorine disinfection with UV.	\$550,000	2028
4	New generator for emergency power	\$311,900	2024
5	Installing a new bio solids dryer system	\$8,000,000	2025
6	Installing new Bio-P mixers, 2 each year over the next three years	\$150,000	2025
7	Removing aging wet well/drywell lift station and replacing it with a submersible pump lift station, also adding approximately 3.5 miles of gravity sanitary sewer	\$3,000,000	2024

5. Financial Management General Comments

ENERGY EFFICIENCY AND USE

6. Collection System

6.1 Energy Usage

6.1.1 Enter the monthly energy usage from the different energy sources:

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 2023

COLLECTION SYSTEM PUMPAGE: Total Power Consumed

Number of Municipally Owned Pump/Lift Stations:

	Electricity Consumed (kWh)	Natural Gas Consumed (therms)
January	4,771	
February	4,127	
March	4,254	
April	5,316	
May	4,651	
June	2,687	
July	2,721	
August	2,945	
September	2,789	
October	2,774	
November	3,246	
December	4,574	
Total	44,855	0
Average	3,738	0

6.1.2 Comments:

6.2 Energy Related Processes and Equipment

6.2.1 Indicate equipment and practices utilized at your pump/lift stations (Check all that apply):

- Comminution or Screening
- Extended Shaft Pumps
- Flow Metering and Recording
- Pneumatic Pumping
- SCADA System
- Self-Priming Pumps
- Submersible Pumps
- Variable Speed Drives
- Other:

6.2.2 Comments:

6.3 Has an Energy Study been performed for your pump/lift stations?

No

Yes

Year:

By Whom:

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 2023

Describe and Comment:

6.4 Future Energy Related Equipment

6.4.1 What energy efficient equipment or practices do you have planned for the future for your pump/lift stations?

We will be replacing an aging lift station with a new submersible pump lift station in June 2024

7. Treatment Facility

7.1 Energy Usage

7.1.1 Enter the monthly energy usage from the different energy sources:

TREATMENT PLANT: Total Power Consumed/Month

	Electricity Consumed (kWh)	Total Influent Flow (MG)	Electricity Consumed/Flow (kWh/MG)	Total Influent BOD (1000 lbs)	Electricity Consumed/Total Influent BOD (kWh/1000lbs)	Natural Gas Consumed (therms)
January	99,967	39.34	2,541	78.00	1,282	5,274
February	112,624	37.07	3,038	77.39	1,455	4,875
March	65,863	40.63	1,621	87.70	751	4,198
April	105,661	43.78	2,413	89.79	1,177	2,383
May	108,503	41.94	2,587	77.87	1,393	386
June	88,384	38.78	2,279	73.77	1,198	63
July	99,166	39.71	2,497	79.86	1,242	76
August	104,134	39.95	2,607	76.32	1,364	71
September	102,294	40.61	2,519	80.97	1,263	152
October	112,207	42.50	2,640	84.32	1,331	1,541
November	124,193	40.50	3,066	79.92	1,554	3,506
December	129,401	41.79	3,096	79.64	1,625	4,125
Total	1,252,397	486.60		965.55		26,650
Average	104,366	40.55	2,575	80.46	1,303	2,221

7.1.2 Comments:

7.2 Energy Related Processes and Equipment

7.2.1 Indicate equipment and practices utilized at your treatment facility (Check all that apply):

- Aerobic Digestion
- Anaerobic Digestion
- Biological Phosphorus Removal
- Coarse Bubble Diffusers
- Dissolved O2 Monitoring and Aeration Control
- Effluent Pumping
- Fine Bubble Diffusers
- Influent Pumping
- Mechanical Sludge Processing
- Nitrification

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 2023

- SCADA System
- UV Disinfection
- Variable Speed Drives
- Other:

7.2.2 Comments:

7.3 Future Energy Related Equipment

7.3.1 What energy efficient equipment or practices do you have planned for the future for your treatment facility?

8. Biogas Generation

8.1 Do you generate/produce biogas at your facility?

No

Yes

If Yes, how is the biogas used (Check all that apply):

- Flared Off
- Building Heat
- Process Heat
- Generate Electricity
- Other:

9. Energy Efficiency Study

9.1 Has an Energy Study been performed for your treatment facility?

No

Yes

Entire facility

Year:

By Whom:

Describe and Comment:

Part of the facility

Year:

By Whom:

Describe and Comment:

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 2023

Study resulted in the fine bubble aeration project which reduced the electric consumption	
---	--

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 2023

Sanitary Sewer Collection Systems

1. Capacity, Management, Operation, and Maintenance (CMOM) Program

1.1 Do you have a CMOM program that is being implemented?

Yes

No

If No, explain:

1.2 Do you have a CMOM program that contains all the applicable components and items according to Wisc. Adm Code NR 210.23 (4)?

Yes

No (30 points)

N/A

If No or N/A, explain:

1.3 Does your CMOM program contain the following components and items? (check the components and items that apply)

Goals [NR 210.23 (4)(a)]

Describe the major goals you had for your collection system last year:

Clean 25% of the collection system
televise 15,000 feet of sewer line
inspect 200 (10%) of man holes
rehab 12 manholes

Did you accomplish them?

Yes

No

If No, explain:

We only cleaned 22% of collection system
Only inspected 160 manholes (8%)

Organization [NR 210.23 (4) (b)]

Does this chapter of your CMOM include:

Organizational structure and positions (eg. organizational chart and position descriptions)

Internal and external lines of communication responsibilities

Person(s) responsible for reporting overflow events to the department and the public

Legal Authority [NR 210.23 (4) (c)]

What is the legally binding document that regulates the use of your sewer system?

City Ordinance

If you have a Sewer Use Ordinance or other similar document, when was it last reviewed and revised? (MM/DD/YYYY) 2016-06-14

Does your sewer use ordinance or other legally binding document address the following:

Private property inflow and infiltration

New sewer and building sewer design, construction, installation, testing and inspection

Rehabilitated sewer and lift station installation, testing and inspection

Sewage flows satellite system and large private users are monitored and controlled, as necessary

Fat, oil and grease control

Enforcement procedures for sewer use non-compliance

Operation and Maintenance [NR 210.23 (4) (d)]

Does your operation and maintenance program and equipment include the following:

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 2023

- Equipment and replacement part inventories
 - Up-to-date sewer system map
 - A management system (computer database and/or file system) for collection system information for O&M activities, investigation and rehabilitation
 - A description of routine operation and maintenance activities (see question 2 below)
 - Capacity assessment program
 - Basement back assessment and correction
 - Regular O&M training
 - Design and Performance Provisions [NR 210.23 (4) (e)]
- What standards and procedures are established for the design, construction, and inspection of the sewer collection system, including building sewers and interceptor sewers on private property?
- State Plumbing Code, DNR NR 110 Standards and/or local Municipal Code Requirements
 - Construction, Inspection, and Testing
 - Others:

City Construction Specifications

- Overflow Emergency Response Plan [NR 210.23 (4) (f)]
- Does your emergency response capability include:
- Responsible personnel communication procedures
 - Response order, timing and clean-up
 - Public notification protocols
 - Training
 - Emergency operation protocols and implementation procedures
- Annual Self-Auditing of your CMOM Program [NR 210.23 (5)]
 - Special Studies Last Year (check only those that apply):
 - Infiltration/Inflow (I/I) Analysis
 - Sewer System Evaluation Survey (SSES)
 - Sewer Evaluation and Capacity Management Plan (SECAP)
 - Lift Station Evaluation Report
 - Others:

2. Operation and Maintenance

2.1 Did your sanitary sewer collection system maintenance program include the following maintenance activities? Complete all that apply and indicate the amount maintained.

Cleaning	<input type="text" value="22"/>	% of system/year
Root removal	<input type="text" value="3"/>	% of system/year
Flow monitoring	<input type="text" value="0"/>	% of system/year
Smoke testing	<input type="text" value="0"/>	% of system/year
Sewer line televising	<input type="text" value="4.8"/>	% of system/year
Manhole inspections	<input type="text" value="8.0"/>	% of system/year
Lift station O&M	<input type="text" value="4"/>	# per L.S./year
Manhole rehabilitation	<input type="text" value="1"/>	% of manholes rehabbed
Mainline rehabilitation	<input type="text" value="0"/>	% of sewer lines rehabbed

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 2023

Private sewer inspections % of system/year
 Private sewer I/I removal % of private services
 River or water crossings % of pipe crossings evaluated or maintained

Please include additional comments about your sanitary sewer collection system below:

We rehabbed 22 manhole of our 12 we wanted to do

3. Performance Indicators

3.1 Provide the following collection system and flow information for the past year.

Total actual amount of precipitation last year in inches
 Annual average precipitation (for your location)
 Miles of sanitary sewer
 Number of lift stations
 Number of lift station failures
 Number of sewer pipe failures
 Number of basement backup occurrences
 Number of complaints
 Average daily flow in MGD (if available)
 Peak monthly flow in MGD (if available)
 Peak hourly flow in MGD (if available)

3.2 Performance ratios for the past year:

Lift station failures (failures/year)
 Sewer pipe failures (pipe failures/sewer mile/yr)
 Sanitary sewer overflows (number/sewer mile/yr)
 Basement backups (number/sewer mile)
 Complaints (number/sewer mile)
 Peaking factor ratio (Peak Monthly:Annual Daily Avg)
 Peaking factor ratio (Peak Hourly:Annual Daily Avg)

4. Overflows

LIST OF SANITARY SEWER (SSO) AND TREATMENT FACILITY (TFO) OVERFLOWS REPORTED **

Date	Location	Cause	Estimated Volume
None reported			

** If there were any SSOs or TFOs that are not listed above, please contact the DNR and stop work on this section until corrected.

5. Infiltration / Inflow (I/I)

5.1 Was infiltration/inflow (I/I) significant in your community last year?

- Yes
- No

If Yes, please describe:

There are a number of clay sewer mains, as we televise and as we find the problems we rate them and try to slip line the worst annually. we do the same with our manhole inspections

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 2023

5.2 Has infiltration/inflow and resultant high flows affected performance or created problems in your collection system, lift stations, or treatment plant at any time in the past year?

Yes

No

If Yes, please describe:

5.3 Explain any infiltration/inflow (I/I) changes this year from previous years:

Due to budget constraints, we couldn't slip line any sewer lines, we did however rehab 22 manholes

5.4 What is being done to address infiltration/inflow in your collection system?

Continue to televise sewer lines and inspect manholes and repair as needed

Total Points Generated	0
Score (100 - Total Points Generated)	100
Section Grade	A

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:

6/4/2024

2023

Grading Summary

WPDES No: 0029394

SECTIONS	LETTER GRADE	GRADE POINTS	WEIGHTING FACTORS	SECTION POINTS
Influent	A	4	3	12
BOD/CBOD	A	4	10	40
TSS	A	4	5	20
Ammonia	A	4	5	20
Phosphorus	A	4	3	12
Biosolids	A	4	5	20
Staffing/PM	A	4	1	4
OpCert	A	4	1	4
Financial	A	4	1	4
Collection	A	4	3	12
TOTALS			37	148
GRADE POINT AVERAGE (GPA) = 4.00				

Notes:

- A = Voluntary Range (Response Optional)
- B = Voluntary Range (Response Optional)
- C = Recommendation Range (Response Required)
- D = Action Range (Response Required)
- F = Action Range (Response Required)

Compliance Maintenance Annual Report

River Falls Municipal Utility Wwtf

Last Updated: Reporting For:
6/4/2024 2023

Resolution or Owner's Statement

Name of Governing
Body or Owner:

City Council

Date of Resolution or
Action Taken:

2024-06-25

Resolution Number:

Date of Submittal:

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO SPECIFIC CMAR SECTIONS (Optional for grade A or B. Required for grade C, D, or F):

Influent Flow and Loadings: Grade = A

Effluent Quality: BOD: Grade = A

Effluent Quality: TSS: Grade = A

Effluent Quality: Ammonia: Grade = A

Effluent Quality: Phosphorus: Grade = A

Biosolids Quality and Management: Grade = A

Staffing: Grade = A

Operator Certification: Grade = A

Financial Management: Grade = A

Collection Systems: Grade = A

(Regardless of grade, response required for Collection Systems if SSOs were reported)

ACTIONS SET FORTH BY THE GOVERNING BODY OR OWNER RELATING TO THE OVERALL GRADE POINT AVERAGE AND ANY GENERAL COMMENTS

(Optional for G.P.A. greater than or equal to 3.00, required for G.P.A. less than 3.00)

G.P.A. = 4.00